



LEGEND: C.I.C.L. Watermain shown
 20mm Copper Tube Branch

NOTES: All work to be executed in accordance with Canberra Sewerage & Water Supply Regulations
 Each branch to finish at the boundary of the easement with meter, path cock & box.
 Anchor blocks shall be provided at 22m spacing on grades exceeding 1 in 14

STAGE 2.
 N.C.D.C. DWG No. 82 10611

COOK ARANDA COOPERATIVE HOUSING SOCIETY

CONSULTING CIVIL & TRAFFIC R.A.D. GOSSIP ENGINEER	UNITS 64-105 SEC.37 COOK HYDRAULIC SERVICES WATER SUPPLY	DATE SCALE 1:500
RG.17-17/75.		